

1 **SUPPLY**

2 **1.0 INTRODUCTION**

3 **Q. What is the purpose of this evidence?**

4 A. This evidence describes the supply resources that are included in the IPSP and outlines
5 how the supply-related requirements of the Supply Mix Directive (the "Directive"), are
6 met.

7 **2.0 DEFINITIONS**

8 **Q. What are Existing, Committed, Directed, and Other Potential Resources?**

9 A. Existing Resources - means those resources that were in commercial operation as of
10 the second quarter of 2011 ("Q2 2011"), or as of August 5, 2011 for FIT resources. The
11 capacity values assumed in the IPSP are equal to the amounts of installed capacity
12 registered with the IESO.

13 Committed Resources - means those resources that are not Existing Resources and
14 were a) non-FIT resources under contract to the OPA as of Q2 2011, or b) FIT
15 resources under contract as of August 5, 2011, or c) the subject of the Green Energy
16 Investment Agreement ("GEIA") entered into between the Government of Ontario and
17 the Korean Consortium. The capacity values assumed in the IPSP are equal to the
18 OPA contract amounts.

19 Directed Resources - means those resources that the government has directed the
20 OPA to plan for and/or procure and that are not Existing or Committed Resources. It
21 includes both specific procurement directives issued to the OPA by the Minister of
22 Energy (or formerly the Minister of Energy and Infrastructure) under section 25.32 of the
23 *Electricity Act, 1998* and those resources for which the government has indicated that it

Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 2 of 29

1 is committed to meet a specified amount¹; because these amounts are specified, they
2 can be modelled for planning purposes. Examples of Directed Resources are
3 renewable generation (including hydroelectric on the one hand and wind, solar and
4 bioenergy on the other) and refurbished and new nuclear generation.

5 Resources whose amount is subject to a decision-making process that is outside of the
6 IPSP are excluded from this category. They are considered to be “Other Potential
7 Resources”.

8 The capacity values assumed in the IPSP are equal to the directed amounts where
9 these are specified, and are otherwise equal to forecast amounts based on available
10 information as of the end of Q2 2011, or as of August 5, 2011 for FIT resources

11 Other Potential Resources - means those resources that are not Existing, Committed or
12 Directed. This category includes new resources whose amount is subject to a decision-
13 making process that is outside of the IPSP. Other Potential Resources include:

- 14 • Additional conservation and demand response in excess of the target amount in the
15 Directive;
- 16 • Additional coal-fired units that could be converted to gas-fired operation as the result
17 of a government decision in 2012 (to about 2,700 MW);
- 18 • Expiring non-utility generation ("NUG") contracts (mostly natural gas-fired
19 generation) that could be renegotiated in accordance with the November 23, 2010,
20 directive (over 1,400 MW by 2023); and
- 21 • Firm (contract) imports that can be accommodated by the Existing transmission
22 capability and the capability of Committed and Directed transmission projects (up to
23 about 1,400 MW). Firm imports may be an alternative option if they meet system
24 requirements at a lower cost than the other available options.

¹ Where the Supply Mix Directive specifies a total amount of a more general resource category (for example, non-hydroelectric renewables and conservation), the sub-components of that amount are treated as Directed Resources.

1 **3.0 DEMAND RESPONSE**

2 **Q. How does the IPSP treat demand response?**

3 A. Conservation is generally divided into five categories: demand response, energy
4 efficiency, fuel switching, conservation behaviour and customer based generation. For
5 planning purposes, the latter four categories of conservation are applied to the load
6 forecast to produce a load forecast that is net of conservation. Demand response (with
7 the exception of time-of-use rate impacts) is not netted from the load forecast. It can be
8 dispatched to meet peak demand requirements. Because of this unique characteristic,
9 it is treated in the IPSP as a dispatchable generator that is available to meet system
10 peak demand requirements. Regardless of this distinction, demand response is a form
11 of conservation that applies to meeting the Supply Mix Directive's conservation targets.

12 **4.0 EXISTING RESOURCES**

13 **Q. What do Existing Resources consist of?**

14 A. Existing Resources consist of all demand response and generation resources in
15 commercial operation as of Q2 2011 or August 5, 2011 for FIT resources, and include:

- 16 • Existing demand response;
- 17 • Existing renewable generation (consisting of existing hydroelectric, wind, bioenergy
18 and solar resources);
- 19 • Existing gas-fired generation;
- 20 • Existing nuclear generation; and
- 21 • Existing coal-fired generation.

22 Together these represent over 35,000 MW of installed capacity. A summary of these
23 resources is shown in Table 1.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 4 of 29

Table 1: Existing Generation Resources as of Q2 2011, or August 5, 2011 for FIT resources


Resource	Commitment/Project	Installed MW
Demand Response	Demand Response I, II, III and Other Direct Load Control Programs	585
Energy from Waste	Non-Utility Generation	8
Wind	Renewable Energy Supply I, II, III	1,412
	Renewable Standard Offer Program	234
	Feed-In Tariff	1
	Other	11
Bioenergy	Non-Utility Generation	113
	Renewable Energy Supply I	9
	Renewable Standard Offer Program	39
	Feed-In Tariff	8
	Other	77
Solar	Renewable Standard Offer Program	213
	Feed-In Tariff and microFIT	75
Hydroelectric	Hydroelectric Contract Initiative	1,055
	Hydroelectric Supply Aggrement	577
	Non-Utility Generation	130
	Renewable Energy Supply I	32
	Renewable Energy Standard Offer Program	28
	Other	6,564
Gas/Oil	Advanced Clean Energy Supply	2,338
	Clean Energy Supply	1,948
	Combined Heat and Power I	481
	Early Movers Clean Energy Supply	1,110
	Lennox	2,100
	Non-Utility Generation	1,521
	Other	100
Nuclear	Bruce NGS	4,828
	Darlington NGS	3,524
	Pickering NGS	3,094
Coal	Various	3,504
Total		35,719

Source: OPA

1 **Q. What are the amounts of the various Existing Resources over the planning**
 2 **period?**

3 A. The installed capacity of Existing Resources declines from over 35,000 MW in 2011 to
 4 about 18,700 MW by 2031. An annual summary of these resources is shown in
 5 Figure 1.

Figure 1: Existing Generation Resources 2011-2031



Source: OPA

6 **5.0 COMMITTED RESOURCES**

7 **Q. What do Committed Resources consist of?**

8 A. Committed Resources are resources that were under contract to the OPA as of
 9 Q2 2011, or August 5, 2011 for FIT resources, or are the subject of the GEIA. They
 10 consist of:

- 11 • Committed renewables other than hydroelectric;
- 12 • Committed hydroelectric renewables;
- 13 • Committed gas-fired generation; and
- 14 • Bruce NGS Units 1 and 2 restart projects.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 6 of 29

1 Together these represent about 9,200 MW of contracted capacity by 2031. A summary
 2 of these resources is shown in Table 2.

Table 2: Committed Generation Resources as of Q2 2011, or August 5, 2011 for FIT resources


Resource	Commitment	Project	Contracted MW
Wind	Renewable Energy Supply III	Greenwich Wind Farm	99
	Renewable Standard Offer Program	Various	85
	Feed-In Tariff	Various	2,350
	Green Energy Investment Agreement	Various	2,000
Solar	Renewable Standard Offer Program	Various	278
	Feed-In Tariff	Various	953
	Green Energy Investment Agreement	Various	500
Bioenergy	Combined Heat and Power III	Becker Cogeneration	15
		St. Marys	30
	Renewable Standard Offer Program	Various	31
	Feed-In Tariff	Various	36
Hydroelectric	Hydroelectric Energy Supply Agreement	Lower Mattagami	438
	Renewable Energy Supply II	Island Falls	20
	Hydroelectric Contract Initiative	Various	4
	Feed-In Tariff	Various	141
Gas	Clean Energy Supply	Greenfield South	280
		York Energy Centre	393
Nuclear	Bruce Power Refurbishment Implementation Agreement	Bruce Unit 1 & 2	1,500
Total			9,154

Source: OPA

3 **Q. What are the amounts of the various Committed Resources over the planning**
 4 **period?**

5 A. The installed capacity of Committed Resources increases from about 300 MW in 2011
 6 to about 9,200 MW by 2031. An annual summary of these resources is shown in
 7 Figure 2.

Figure 2: Committed Generation Resources 2011-2031



Source: OPA

1 **6.0 DIRECTED RESOURCES**

2 **Q. What do Directed Resources consist of?**

3 A. Directed Resources are resources that the government has directed the OPA to plan for
 4 and/or procure and that are not in commercial operation or under contract as of
 5 Q2 2011. They consist of:

- 6 • The demand response component of the conservation target that is not an Existing
 7 Resource;
- 8 • Renewables other than hydroelectric resources including bioenergy resources
 9 procured under the Combined Heat and Power (“CHP”) III program, the Atikokan
 10 Biomass Energy Supply Agreement and additional resources (solar, bioenergy and
 11 wind) required to meet the 10,700 MW non-hydroelectric renewables target in the
 12 Supply Mix Directive;
- 13 • Hydroelectric resources required to meet the 9,000 MW hydroelectric generation
 14 target in the Directive;
- 15 • Conversion of two units at Thunder Bay Generating Station (“GS”) to run on natural
 16 gas, procurement of a natural gas-fired plant in the Kitchener-Waterloo-Cambridge
 17 area, and other CHP procurements to meet the Supply Mix and CHP Directives;

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 8 of 29

- 1 • Refurbishment of existing Bruce Units 3 to 8 and the Darlington station; and
- 2 • New nuclear generation.

3 Together these represent about 15,500 MW of directed or forecast capacity by 2031. A
 4 summary of these resources is shown in Table 3.

Table 3: Directed Generation Resources as of Q2 2011, or as of August 5, 2011 for FIT resources


Resource	Commitment	Project	IPSP
Demand Response	Demand Response I, II, III and Other Direct Load Control Programs	Various	1,608
Energy from Waste	Other	Durham-York Energy Centre	20
Wind	FIT and microFIT Forecast	Various	843
Bioenergy	Atikokan Biomass Energy Supply Agreement	Atikokan	201
	Combined Heat and Power III	Thunder Bay Condensing Turbine	40
	FIT and microFIT Forecast	Various	8
Solar	FIT and microFIT Forecast	Various	1,100
Hydroelectric	Other	Various upgrades	17
Gas	Coal to Gas Conversion	Thunder Bay	304
	Future Combined Heat and Power Procurement	Various	500
	Peaking Generation	Kitchener-Waterloo-Cambridge	450
Nuclear	Refurbishment	Darlington NGS	3,524
		Bruce A NGS	1,540
		Bruce B NGS	3,288
	New Nuclear	Darlington NGS	2,000
Total			15,443

Source: OPA

5 **Q. What are the amounts of the various Directed Resources over the planning**
 6 **period?**

7 A. The installed capacity of Directed Resources increases from about 400 MW in 2011 to
 8 about 15,500 MW by 2031. An annual summary of these resources is shown in
 9 Figure 3.

Figure 3: Directed Generation Resources 2011-2031



Source: OPA

1 **7.0 MEETING DIRECTIVE REQUIREMENTS**


2 **7.1 Demand Response**

3 **Q. What is the Directive requirement with respect to Demand Response and what**
 4 **amount is included in the IPSP?**

5 A. The total conservation target in the Directive is for a peak demand reduction of
 6 7,100 MW by the end of 2030. The Directive does not prescribe a load reduction target
 7 that is specific to demand response resources. The IPSP includes about 1,000 MW of
 8 load reduction through demand response in 2011, increasing to about 1,700 MW by
 9 2031, as shown in Figure 4.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 10 of 29

Figure 4: Demand Response Resources in the IPSP



Source: OPA

1 **7.2 Nuclear Generation**

2 **Q. What is the Directive requirement with respect to nuclear generation?**

3 A. The Supply Mix Directive states that :


- 4 • The OPA shall continue to plan for nuclear generation to account for approximately
- 5 50% of total Ontario electricity generation;
- 6 • The IPSP shall provide for the refurbishment of 10,000 MW of existing nuclear
- 7 capacity at the Bruce NGS and the Darlington NGS;
- 8 • The OPA shall continue to work with OPG, Bruce Power and the Ministry of Energy
- 9 to ensure that the IPSP contains an updated coordinated refurbishment schedule;
- 10 and
- 11 • The IPSP shall provide for the procurement of two nuclear generating units
- 12 (approximately 2,000 MW) at the Darlington site.

13 **Q. How does the IPSP meet the Directive requirement for nuclear generation to**
 14 **account for approximately 50% of total Ontario electricity generation?**

15 A. Nuclear energy in the IPSP accounts for approximately 50% of total Ontario energy
 16 generation by 2031, as shown in Figure 5. The maximum value is about 60% in the

1 period when Pickering units are in service and is reduced to less than 50% in the mid-
 2 term while units at Bruce NGS and Darlington NGS are being refurbished.

Figure 5: Annual Nuclear Generation as a Percent of Total Ontario Energy Generation



Source: OPA

3 **Q. How does the IPSP provide for the refurbishment of 10,000 MW of existing**
 4 **nuclear capacity at the Bruce Nuclear GS and the Darlington GS?**

5 A. The IPSP includes approximately 10,000 MW of refurbished nuclear capacity. This
 6 consists of eight units at Bruce NGS (totalling about 6,300 MW) and four units at
 7 Darlington NGS (totalling about 3,500 MW).

8 **Q. How did the OPA work with OPG, Bruce Power and the Ministry of Energy to**
 9 **ensure that the IPSP contains an updated coordinated refurbishment schedule?**

10 A. Since 2009, the OPA has been working with OPG, Bruce Power and the Ministry of
 11 Energy as part of the Nuclear Refurbishment Coordination Working Group (“NRCWG”)
 12 in developing a coordinated nuclear refurbishment schedule. The objective of this
 13 group is to develop a schedule that maximizes the concurrent availability of the nuclear
 14 fleet during those periods of highest value to the system, based on refurbishment
 15 planning being performed at each of OPG and Bruce Power, and with consideration of
 16 each of their units’ respective end of life. This is an ongoing process that facilitates plan
 17 implementation, monitoring, and adjustment as necessary to reflect changing

Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 12 of 29

1 conditions. As part of the activities of this group, an updated coordinated refurbishment
2 schedule was developed for the IPSP.

3 **Q. What is the coordinated nuclear refurbishment schedule and how was it**
4 **determined?**

5 A. The coordinated nuclear refurbishment schedule is a schedule for the refurbishment of
6 Bruce Units 3 to 8 and Darlington Units 1 to 42 that maximizes the concurrent
7 availability of the nuclear fleet during those periods of highest value to the system. This
8 is accomplished by minimizing the overlap of refurbishment outages and allocating the
9 remaining operating hours to high-value periods.


10 The NRCWG used two criteria in developing the refurbishment schedule: 1) there
11 should be no more than two concurrent outages at each site, and 2) there should be no
12 more than four concurrent outages at any point in time. These criteria reflect the
13 limitations on the availability of resources and a skilled workforce that constrain the
14 number of units that can be concurrently refurbished. To maximize the availability of
15 nuclear units while minimizing idle time,³ it is necessary to begin refurbishing some
16 units in advance of their end-of-service life. In this case, the refurbished units would be
17 available earlier to meet resource requirements while other nuclear units are being
18 refurbished.

19 The assumed duration of individual refurbishment outages ranges from 30 months to
20 36 months and results in the profile of unavailable nuclear capacity shown in Figure 6.

² The units at Bruce NGS and Darlington NGS came into service beginning in the late 1970s through the early 1990s and most are expected to reach their end-of-service life between 2016 and 2020. Currently, refurbishments are underway at Bruce A units 1 and 2, and their expected commercial operation date is 2012.

³ Idle time occurs during periods when units are not operational because they have reached their end-of-service life but cannot be refurbished because of workforce constraints.

Figure 6: Total Unavailable Nuclear Capacity at Bruce NGS and Darlington NGS in IPSP at System Peak



Source: OPA

1 **Q. How does the IPSP provide for the procurement of two nuclear generating units**
 2 **at the Darlington site?**

3 A. The IPSP provides for the addition of two nuclear units totalling 2,000 MW, to be placed
 4 in service at the existing Darlington site in 2022 and 2023 respectively. OPG is
 5 currently in the process of completing the environmental assessment and obtaining a
 6 site preparation license at Darlington.

7 The 2022 in-service date for the first unit is considered to be the earliest feasible in-
 8 service date based on a 10-year lead time requirement for new nuclear generation.
 9 New nuclear generation contributes to meeting the Capacity Gap created by nuclear
 10 refurbishments during the period 2022 to 2023 and addresses the Capacity Gap that
 11 would otherwise exist during the period from 2024 to 2027 under the medium-load
 12 growth scenario. The Capacity Gap is discussed more fully in Exhibit F-1-1.

Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 14 of 29

1 The actual in-service date will be determined by the government based on its
2 procurement activities. Given the long-term nature of energy infrastructure investments,
3 delaying the in-service date for these facilities will not have a material impact on the
4 choice respecting alternative facilities which generally have shorter lead time
5 requirements. Accordingly, the 2022 in-service date is relied on for planning purposes
6 only.

7 **7.3 Coal-Fired Generation**

8 **Q. What are the Directive requirements with respect to coal-fired generation?**

9 A. The Supply Mix Directive notes that since 2003, Ontario has shut down eight coal-fired
10 generating units. These include the Lakeview GS and two units each at OPG's
11 Nanticoke and Lambton GS. It also notes that the shutdown of two additional units at
12 Nanticoke GS will take place before the end of 2011, and reaffirms that the
13 government's commitment to replace all coal-fired generation by the end of 2014 will be
14 met.

15 The Supply Mix Directive requires the OPA to:

- 16 • Negotiate with OPG for a contract for biomass-fuelled generation from the 201 MW
17 Atikokan GS in northwestern Ontario (this is addressed in a procurement directive);
- 18 • Work with the IESO and OPG to determine opportunities for advancing the closure
19 of additional units;
- 20 • Plan for two units at OPG's Thunder Bay GS to be converted to run on natural gas
21 over the period leading up to 2014; and
- 22 • Assess the conversion of some or all of the remaining units at Lambton and
23 Nanticoke GS to natural gas under a range of different scenarios for nuclear
24 generation and system peaking requirements.

25 The Thunder Bay Generating Station Conversion Directive (August 17, 2011) requires
26 the OPA to:

- 27 • Negotiate and execute an Agreement with OPG by December 31, 2011 whose
28 financial terms are “commercially reasonable for a facility being converted from coal

1 to natural gas of the size and location of the Thunder Bay Generating Station”.

2 **Q. How does the IPSP provide for the conversion of Atikokan GS to biomass?**

3 A. The IPSP assumes that Atikokan will be converted to biomass operation in 2013 as
4 specified in the Supply Mix Directive with a capacity of approximately 200 MW and an
5 annual production of approximately 140 GWh.

6 **Q. How has the OPA worked with the IESO and OPG to determine opportunities for
7 advancing the closure of additional units and converting some of the Lambton
8 and Nanticoke coal units to natural gas to meet peaking requirements?**

9 A. The OPA has coordinated studies by the IESO and OPG to determine opportunities for
10 advancing the closure of additional units and the optimal timing of converting some of
11 the remaining units to natural gas, if a government decision is made to do so.

12 At the OPA's request, the IESO (with input from OPG) conducted a study to determine
13 the earliest feasible dates for the closure of Lambton and Nanticoke as coal-fired units,
14 based on reliability considerations. The study also examined feasible schedules for the
15 conversion of Lambton GS and Nanticoke GS to natural gas considering plant-specific
16 lead-time requirements provided by OPG and system operation impacts identified by
17 the IESO. The IESO study was based on operational planning considerations to ensure
18 adequacy of supply under a range of different scenarios for nuclear generation and
19 system peaking requirements, and recognizing the potential unavailability of other
20 generating units due to ongoing planned maintenance and unforeseen events.
21 Additional details can be found at Exhibit D-1-4.

22 The IESO report concludes that for system reliability the earliest coal closure dates are
23 as follows:

24 *Earliest Coal Closure Dates*

25 *Lambton: Unit 3 - Q3 2013; Unit 4 - Q4 2013*

Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 16 of 29

1 *Nanticoke: Unit 5 - Q2 2014; Unit 6 - Q3 2014; Unit 7- Q4 2014; Unit 8 - end of Q4 2014*

2 The IESO report also concludes that the optimal completion dates for gas conversion
3 based on system reliability and plant-specific considerations are as follows:

4 *Gas Conversion Completion Dates*

5 *Lambton: Unit 3 – Q3 2015; Unit 4 – Q1 2016*

6 *Nanticoke: Unit 5 – Q1 2015; Unit 6 – Q1 2015; Unit 7 – Q2 2015; Unit 8 – Q3 2015*

7 **Q. What system reliability and plant-specific factors influence the timing of gas**
8 **conversions?**

9 A. As indicated, the government will determine whether to convert some or all of the
10 remaining coal facilities to gas-fired operation in 2012. This timeframe will allow
11 government to consider whether and to what extent these facilities should contribute to
12 meeting the Capacity Gap described in Exhibit F-1-1.

13 The timing required to achieve the conversion schedule above as identified in the IESO
14 study requires that a decision on Nanticoke and Lambton conversion be made by the
15 first quarter of 2012. However, due to the long lead-times associated with a natural gas
16 supply to Nanticoke, technical and environmental studies for a pipeline have already
17 commenced.

18 Should the government determine that the coal facilities should be converted to natural
19 gas, input from OPG and the IESO indicates that:

- 20 • conversion outages require careful coordination in order to ensure that system
21 reliability can be maintained;
- 22 • shutting down coal units and delaying their conversion to natural gas could result in:
- 23 • Risk and cost of equipment degradation due to layup and disuse;
- 24 • Cost and schedule challenges from de-staffing and re-staffing hundreds of
25 employees; and

- Environmental assessment requirements and associated costs if units are shut down without immediate conversion to a new fuel.

Q. How does the IPSP reflect the requirement for two units at Thunder Bay Generating Station to be converted to run on natural gas over the period leading up to 2014?

A. The IPSP is based on Thunder Bay Unit 3 being available for operation on natural gas approximately three years after receiving a conversion directive. A directive for the conversion of Thunder Bay GS units to gas-fired operation was received on August 17, 2011. Accordingly, preliminary information provided by OPG indicates that the Unit 3 conversion outage would start at the beginning of Q2, 2014 and would be complete by the end of Q3, 2014. The Unit 2 conversion outage would start at the beginning of Q1, 2015 and would be complete by the end of Q2, 2015. These dates are conditional on timely project contracts and approvals being obtained. They are consistent with IESO requirements to maintain reliability of supply to the northwest system following the closure of Thunder Bay GS and Atikokan GS as coal-fired generation stations by 2014 (see Exhibit D-1-3).

7.4 Hydroelectric Resources

Q. What is the Directive requirement with respect to hydroelectric resources?

A. The Supply Mix Directive notes that new hydroelectric developments are underway by OPG including the Niagara Tunnel and the 440 MW Lower Mattagami redevelopment, as well as additional private sector developments. It directs the OPA to:

- Plan for installed hydroelectric capacity to reach 9,000 MW by 2018;
- Continue to explore cost-effective opportunities for further hydroelectric development and maximize existing hydroelectric resources; and plan to provide for hydroelectric generation to account for approximately 20 to 25% of total Ontario electricity generation.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 18 of 29

Q. How does the IPSP address the requirement for installed hydroelectric capacity to reach 9,000 MW by 2018?

A. The IPSP includes approximately 9,000 MW of hydroelectric capacity, consisting almost entirely of Existing Resources. The 123 MW Pump Generating Station (“PGS”) at Sir Adam Beck is included to meet the hydroelectric target. These are summarized in Table 4.

Table 4: Summary of Hydroelectric Resources to Meet Target of 9,000 MW by 2018

Resource	Status	Commitment	Project	MW
Hydroelectric	Existing	--	Various	8,379
	Committed	Renewable Energy Supply II	Island Falls	20
		Hydroelectric Energy Supply Agreement	Lower Mattagami	438
		Feed-In Tariff	Various	141
		Hydroelectric Contract Initiative	Various	4
	Directed	Other	Various Upgrades	17
Total				9,000

Source: OPA

The FIT Program projects included in Table 4 are those that can be connected to Existing transmission and Committed transmission projects. The IPSP assumes that over 8,800 MW of non-FIT Existing and Committed hydroelectric resources would remain in service or proceed to commercial operation by 2018. It is assumed that contracted and future FIT projects will contribute to meeting the 9,000 MW hydroelectric generation target, after taking attrition into consideration.

Q. What cost-effective opportunities exist for further hydroelectric development and maximizing existing hydroelectric resources?

A. In addition to the 9,000 MW target, potential cost-effective opportunities for hydroelectric development may arise from a number of sources including:

- Projects that are currently under consideration including Little Jackfish (73 MW) and New Post Creek (25 MW). These projects involve an equity partnership between OPG and First Nations.

- 1 • FIT Program projects under 50 MW that are not included in Table 4 and are not
2 counted towards meeting the 9,000 MW target.
- 3 • Additional potential projects include:
 - 4 • the redevelopment or upgrade of existing facilities;
 - 5 • greenfield projects in the pre-development stage;
 - 6 • active First Nation-led projects in proximity to the Ring of Fire;
 - 7 • new projects enabled by the connection of remote communities; and
 - 8 • sites that may become available as a result of the deregulation of certain
9 parks and protected areas.

10 An advisory group to the OPA consisting of First Nations and Métis community
11 representatives and stakeholders will be established to facilitate the development of
12 non-FIT hydroelectric projects. This advisory group will identify and explore the cost-
13 effectiveness of projects to maximize the capability of existing hydroelectric facilities and
14 the cost-effectiveness of potential new hydroelectric projects - such as Little Jackfish,
15 New Post Creek, and other hydroelectric projects that are currently in the development
16 stage.

17 Initially, terms of reference will be established which will include developing guidelines
18 for evaluating project cost-effectiveness and developing a process by which potentially
19 cost-effective hydroelectric resources will be identified and assessed by the OPA. Cost-
20 effectiveness will be determined on the basis of all-in life-cycle costs, including
21 transmission investments required to enable incorporation of future projects.


22 The work of this advisory group will be informed by, and will be consistent with, any
23 revisions to the FIT program that result from the two-year review cycle. The results of
24 this work will inform future IPSPs and advice to government.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 20 of 29

1 **Q. Does the IPSP provide for hydroelectric generation to account for approximately**
 2 **20 to 25% of total Ontario electricity generation?**

3 A. By 2018, total Ontario energy generation from hydroelectric resources during the period
 4 of nuclear refurbishment outages represents 28 to 31% of total generation as shown in
 5 Figure 7. By 2028, hydroelectric resources represent 25% of total generation.

Figure 7: Annual Hydroelectric Generation as a Percent of Total Ontario Generation



Source: OPA

6 **7.5 Non-Hydroelectric Renewable Resources**

7 **Q. What are non-hydroelectric renewable resources?**

8 A. Non-hydroelectric renewable resources are those facilities that generate electricity from
 9 natural resources other than water. These resources include wind, solar and bio-
 10 energy.

11 **Q. What is the Directive requirement for non-hydroelectric renewable resources?**

12 A. The Supply Mix Directive provides that:

- 13 • The OPA shall plan for 10,700 MW of non-hydroelectric renewable capacity by 2018;
 14 and
- 15 • The Plan shall provide for non-hydroelectric renewable energy to account for
 16 approximately 10 to 15% of total Ontario electricity generation by 2018.

1 The government will look for opportunities to incorporate additional capacity from
 2 renewable energy facilities into the Plan, taking into consideration cost-effectiveness for
 3 Ontario electricity consumers, planned transmission additions, and electricity demand
 4 growth.

5 **Q. How does the IPSP meet the Directive requirement to plan for 10,700 MW of non-**
 6 **hydroelectric renewable capacity by 2018?**

7 A. The IPSP includes approximately 10,700 MW of non-hydroelectric renewables by 2018.
 8 This consists of Existing, Committed and Directed solar, wind and bio-energy resources
 9 as shown in Table 5.

Table 5: Summary of Non-Hydroelectric Resources to Meet Target of 10,700 MW by 2018

Resource Type	Status	Commitment	Project	IPSP MW	
Wind	Existing	Existing	Various	1,658	
	Committed	Renewable Energy Supply III		Greenwich Windfarm	99
		Renewable Energy Standard Offer Program		Various	85
		Feed-In Tariff		Various	2,350
		Green Energy Investment Agreement		Various	2,000
	Directed	FIT and microFIT Forecast		Various	843
Total				7,035	
Solar	Existing	Existing	Various	288	
	Committed	Renewable Energy Standard Offer Program		Various	278
		Feed-In Tariff		Various	953
		Green Energy Investment Agreement		Various	500
	Directed	FIT and microFIT Forecast		Various	1,100
Total				3,119	
Bioenergy	Existing	Existing	Various	185	
	Committed	Combined Heat and Power III		Becker	15
				St. Mary's	30
		Renewable Energy Standard Offer Program		Various	31
		Feed-In Tariff		Various	36
	Directed	Combined Heat and Power III		Thunder Bay Condensing Turbine	40
		Atikokan Biomass Energy Supply Agreement		Atikokan	201
FIT and microFIT Forecast		Various	8		
Total				546	
Total				10,700	

Source: OPA


Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 22 of 29

1 The FIT projects shown in Table 5 are those that can be connected to Existing
2 transmission and Committed and Directed transmission projects. The IPSP assumes
3 that over 5,300 MW of non-FIT Existing, Committed, and Directed non-hydroelectric
4 renewable resources will remain in service or proceed to commercial operation by 2018.
5 The remainder of the 10,700 MW target is assumed to be met through a combination of
6 contracted and future FIT generation, taking into account the potential for project
7 attrition and the transmission capability afforded by the new Bruce to Milton
8 transmission line and the Directed transmission projects. For IPSP planning purposes,
9 the 10,700 MW target amount of non-hydroelectric renewables is assumed to be
10 maintained for the remainder of the IPSP period. This is not meant to preclude the
11 identification and development of future additional cost-effective non-hydroelectric
12 projects.

13 **Q. Does the IPSP provide for non-hydroelectric renewable energy to account for**
14 **approximately 10 to 15% of total Ontario electricity generation by 2018?**

15 A. During the period of nuclear refurbishment outages, total Ontario energy generation
16 from non-hydroelectric renewable resources is expected to represent about 16% to 18%
17 of total generation as shown in Figure 8. As the nuclear units are refurbished and
18 nuclear production is restored to the levels before refurbishment, the proportion of non-
19 hydroelectric renewable generation settles at about 14% in 2024 and remains at that
20 level for the remainder of the IPSP period.

Figure 8: Annual Non-Hydroelectric Renewable Generation as a Percent of Total Ontario Electricity Generation



Source: OPA

Q. What opportunities exist to incorporate additional cost-effective non-hydroelectric renewables into the IPSP?

A. In addition to the 10,700 MW of non-hydroelectric renewables included in the IPSP by 2018, there may be potential opportunities to incorporate additional cost-effective non-hydroelectric renewables. These may include:

- FIT Program projects awaiting assessment; and/or
- Cost-effective renewable potential in resource rich regions of the province.

Following the Bruce to Milton allocation, over 7,000 MW of non-hydroelectric capacity allocation required (“CAR”) FIT Program applications were awaiting Economic Connection Test assessment. It is anticipated that approximately 950 MW of non-hydroelectric CAR projects beyond current commitments could be accommodated on Existing, Committed and Directed transmission facilities and have been included in the IPSP to meet the 2018 target.

In the longer term, there is significant resource potential throughout the province for additional wind, bioenergy, and solar generation to be considered as options in meeting planning requirements. Previous studies have identified significant on-shore and off-

Filed: Date, 2011
EB-2011-0220
Exhibit D
Tab 1
Schedule 1
Page 24 of 29

1 shore wind potential.^{4,5} An assessment of small-scale distributed biomass electricity
2 generation potential in Ontario has identified at least 1,000 MW of biomass power
3 generation potential (see Exhibit D-1-2). Ontario’s wide geography and relatively strong
4 solar irradiance also provide for significant solar potential.

5 **7.6 Gas-Fired Resources**

6 **Q. What is the Supply Mix Directive requirement with respect to gas-fired** 7 **generation?**

8 A. The Supply Mix Directive provides that the OPA shall continue to plan on natural gas to:

- 9 • Play a strategic role in Ontario’s supply mix by complementing intermittent supply,
10 meeting local and system requirements, and ensuring that adequate capacity is
11 available as nuclear plants are modernized; and
- 12 • As indicated in the 2007 IPSP, meet adequate regional electricity supply in the
13 Kitchener-Waterloo-Cambridge area.

14 **Q. How does the IPSP meet the Directive requirements for gas to play a strategic** 15 **role in Ontario’s supply mix by complementing intermittent supply, meeting local** 16 **and system requirements, and ensuring that adequate capacity is available as** 17 **nuclear plants are modernized?**

18 A. The IPSP includes the Greenfield South (280 MW CCGT)⁶, York Energy Centre
19 (393 MW SCGT) and Kitchener-Waterloo-Cambridge (450 MW SCGT) projects. These
20 projects meet system needs for flexible peaking capacity to meet reliability requirements
21 as coal-fired generation is shutdown and nuclear plants are refurbished. They are also
22 required to complement increasing amounts of intermittent wind and solar generation
23 that are being added to the system. They are strategically sited in high-value locations
24 that defer or replace the need for local area transmission enhancements.

⁴ Analysis of Future Wind Farm Development in Ontario. Helimax Energy Inc. March 2006.
http://www.powerauthority.on.ca/sites/default/files/page/4535_D-5-1_Att_1.pdf

⁵ Analysis of Future Offshore Wind Farm Development in Ontario. Helimax Energy Inc. April 2008.
http://www.powerauthority.on.ca/sites/default/files/page/6446_D-5-2_Att_1_Helimax_Analysis_FINAL.pdf

⁶ The government announced in September 2011 that the Greenfield South plant, owned by Eastern Power Ltd., would be relocated.

7.7 Procurement Directives

Q. What other directive requirements relate to gas-fired generation?


A. Two directives issued on November 23, 2010 relate to gas-fired generation:

- The NUG directive directs the OPA to negotiate for new contracts with the owners or operators of the NUGs where these would have cost and reliability benefits to Ontario electricity customers (these facilities mostly consist of natural-gas fired generation); and
- The CHP directive directs the OPA to procure up to a total of 1,000 MW of CHP projects. This would be inclusive of CHP projects procured to date, individually negotiated CHP contracts with projects over 20 MW and CHP projects 20 MW or less procured through a standard offer program.

Q. How does the IPSP reflect the NUG Procurement Directives?

A. The need for natural gas-fired NUG facilities will be determined in the context of the consideration of Other Potential Resources that are available to meet the mid-term Capacity Gap. As such, no NUG capacity is incorporated as Directed Resource capacity at this time. This is addressed in the context of the Capacity Gap described at Exhibit F-1-1. The amount of NUG capacity included in the IPSP is shown in Figure 9. The capacity of hydroelectric and biomass non-utility generators whose contract term expires after 2018 was assumed to be replaced so that the level of renewable resources achieved to meet the 2018 targets is maintained over the period of the IPSP.

Figure 9: NUG Capacity Included in the IPSP (MW)




Source: OPA

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 26 of 29

Q. How does the IPSP reflect the CHP Procurement Directive?

A. As described above, the CHP Directive requires procurement of 1,000 MW of CHP resources. To date, the OPA has procured a contract amount of about 500 MW of CHP; there is therefore a requirement to procure approximately 500 MW of additional natural gas-fired CHP facilities to satisfy this directive. The Existing, Committed, and Directed CHP contract capacity is shown in Figure 10.

Figure 10: CHP Contract Capacity (MW)



Source: OPA

Q. What other procurement directives relate to hydroelectric generation?

A. The Hydroelectric Contracting Initiative Directive ("HCI Directive") issued May 7, 2009 directs the OPA to enter into new contracts for hydroelectric facilities that are connected to the IESO-controlled grid but not currently owned by OPG. The hydroelectric facilities must not have been previously considered under any renewables RFP. Facilities with or without a current contract with a provincial government body or agency, for any part of the generation output, may participate. A new contract for a currently contracted facility will not start until after the existing contract expires.

1 **Q. How does the IPSP reflect the HCI Directive?**

2 A. The IPSP includes 1,055 MW of Existing hydroelectric generation procured under the
3 HCI Directive.

4 **7.8 Electricity Storage**


5 **Q. How does the IPSP consider electricity storage?**

6 A. The IPSP assumes that the pumped storage facility at Sir Adam Beck PGS rated at
7 123 MW of generating potential will continue to operate throughout the Plan period.

8 Pumped storage can provide several benefits to the electricity system; it can shift lower
9 cost electricity to higher value periods (a specific example is the mitigation of periods of
10 potential surplus energy), it can provide peaking capacity, and it can provide ancillary
11 services including frequency regulation and ramping. Exhibit D-1-5 outlines various
12 storage technologies that can be used in electricity systems and their potential
13 applications. They are summarized in Figure 11 below.

Filed: Date, 2011
 EB-2011-0220
 Exhibit D
 Tab 1
 Schedule 1
 Page 28 of 29

Figure 11: Overview of Storage Technologies



Energy Storage Acronyms and Abbreviations					
CAES	Compressed Air Energy Storage	NiCd	Nickel-Cadmium	VRB	Vanadium Redox
Li-ion	Lithium Ion	NiMH	Nickel-metal hydride	Zn-Air	Zinc-Air
NaNiCl ₂	Sodium Nickel Chloride	PSB	Polysulfide Bromide	Zn-Br	Zinc-Bromide
NaS	Sodium Sulfur	SMES	Superconducting Magnetic Energy Storage	Zn-Cl	Zinc-Chloride

Source: EPRI

1 At this point, the economics do not support the addition of electricity storage at the bulk
 2 system level. Many storage technologies are still in the development lifecycle phase.
 3 As the benefits of electricity storage evolve it is anticipated that individual customers,
 4 load aggregators, and possibly local distribution companies will find opportunities for
 5 development of electricity storage systems at the local level. The OPA continues to
 6 recommend a strategy for storage that maximizes value from existing storage facilities
 7 and to build on our understanding of its benefits as well as its role in meeting system
 8 needs before any new major capital investments are made. The strategy is based on
 9 managing risk for the ratepayer. It recognizes that storage tends to require high up-

1 front capital investments and long lead times to build as well as to yield a net positive
2 contribution to customer rates.

3 Given that Existing, Committed, Directed and Other Potential Resources are sufficient
4 to meet the identified needs, the IPSP does not include any additional electricity storage
5 facilities.

6 **8.0 SCHEDULES**

7 The following exhibits are associated with this Supply evidence:

- 8 • Exhibit D-1-2: Assessment of Small-Scale Distributed Biomass Electricity
9 Generation Potential in Ontario;
- 10 • Exhibit D-1-3: Northwest Coal Conversion Reliability Assessment;
- 11 • Exhibit D-1-4: Southwestern Ontario Coal: Advance Shutdown/Conversion
12 Assessment; and
- 13 • Exhibit D-1-5: Electricity Storage.